



EDUCATION DEPARTMENT
GOVERNMENT OF SIKKIM
GANGTOK

Memo No. 644/OE(EI)ED/Edu.

Date 22/03/2023


BUILDING SAFETY CERTIFICATE


This is to Certify that a physical inspection of **Holy Cross School, having CBSE Affiliation No. 1830002** located at **6th mile ,Tadong** in **East Sikkim** was conducted on 21st of March 2023 by the field engineer of Education Department East-I, where it was found that the above mentioned school has five R.C.C framed structures with following details mention below:-

1. Main building:- R.C.C building comprises of three storeyed with G.C.I sheet roofing having 23 rooms for academic purposes, the built in plinth area is 7,422ft².
2. Science block :-R.C.C building comprises of two storeyed with G.C.I sheet roofing having 8 rooms for academic purposes, the built in plinth area is 3,402.65ft².
3. Class 6th block (Middle section):- R.C.C building comprises of two storeyed with G.C.I sheet roofing having 8 rooms for academic purposes, the built in plinth area is 3,264ft².
4. Primary block:- R.C.C building comprises of three storeyed with G.C.I sheet roofing having 25 rooms for academic purposes, the built in plinth area is 10,276.8 ft².
5. Auditorium:- R.C.C building comprises of single storeyed with G.C.I sheet roofing with built in plinth area is 6,706.20ft².

The visual inspection revealed that the columns, beams and slab had no cracks or shear stress of any kind, the partitions were also found to be free from cracks. Till date the school buildings has no significant damages and defects. Hence, the structure can be certified to be fairly safe.

This certificate is valid for a period of one year from the date of issue


Assistant Engineer, East-I
Education Department
Govt. of Sikkim


Divisional Engineer, East-I
Education Department
Govt. of Sikkim